

TERCÜME
TRANSLATION
ÜBERSETZUNG

HEADSHIP OF TSE TEST and CALIBRATION CENTER
CONSTRUCTION MATERIALS FIRE AND ACOUSTIC LABORATORY

AB-0001-T
605387
04-21

REACTION TO FIRE CLASSIFICATION

Class of the ALBOND 9000 FR Series product, determined according to its behavior when exposed to fire:

B

Class of the ALBOND 9000 FR Series product, determined according to its smoke-inducing properties:

s1

Class of the ALBOND 9000 FR Series product, determined according to its flame drops inducing properties:

d0



Fire Behavior	Smoke Production	Flame Drops
B	s1	d0

Reaction to Fire Classification: B-s1, d0

4.3 Application Field

This classification is valid for products with the same formulation, of the same type, with the same name, under the final application conditions specified below.

Final Application

Fixing	Fixing to metal bearing profiles and frames with fireproof fasteners
Air gap behind the product	Applications that leave an 80 mm or bigger air gap behind the product
Joint part	Applications with or without joints vertically and/or horizontally; Applications where no filling material is used at the joints

5 Limitations

Upon the publication of the TS EN 13501-1:2019 standard, there is no decision on the term of validity of the classification report.

This classification report is not a type of approval or certification of the product and may not be used in replacement of such document.

End of classification report

Uğur ZİREK
Yeminli Tercüman (Certified Translator)
Reşadiye Mahallesi Kumyol Caddesi Kardeşler İş Mkt.
Kat: 2 D.: 8 Çorlu/TEKİRDAĞ Tel.: 0(282) 653 56 26
Çorlu Vergi Dairesi : 63844054318

(Seal)